



Pimpri Chinchwad Municipal Corporation
Pimpri, Pune - 411018.
Phone :- 020- 67331110/1120
Fax :- 020- 27425600
E-Mail :- commissioner@pcmcindia.gov.in
Web :- www.pcmcindia.gov.in

NO - ws/lab/154/2026

Date - 07/05/2026

To

The Principal,

Rasiklal M. Dhariwal International School,

Chinchwad.

Subject: Water sample Potability Certificate.

Drinking water sample provided by Rasiklal M. Dhariwal International School, Chinchwad on Date: 05/05/2026 was analysed for Chemical and Bacteriological analysis. As per the analysis reports no. ws /lab /149/2026 dated 06/05/2026 & ws /lab /150/2026 dated 06/05/2026 the water Samples are safe for drinking purpose.

The Bacteriological & chemical analysis reports are attached herewith.

Note-The water sample not drawn by this laboratory


CHIEF CHEMIST
Water Treatment Plant
Pimpri Chinchwad Municipal Corp.
Nigdi, Pune 44

PIMPRI CHINCHWAD MUNICIPAL CORPORATION



(W/S) DIVISION

REPORT OF BACTERIOLOGICAL EXAMINATION OF WATER

No-WS/LAB/150 /2026.

Date - 06 / 05 /2026.

NAME - Rasiklal M. Dhariwal International School. DATE OF EXAMINATION - 05 /05/2026.

ADDRESS - Chinchwad.

SOURCE - PCMC Water.

SR.NO.	WATER SAMPLE (PLACE)	RESIDUAL CHLORINE (PPM)	CONCLUSION MPN/100ml		REMARK
			Coliforms	E.Coli	
1	Water Sample	0.4 ppm	0/100ml	-	Potable.
2					 CHIEF CHEMIST Water Treatment Plant Pimpri Chinchwad Municipal Corp. Nigdi, Pune 44
3					
4					
5					
6					
7					
8					
9					
10					
11					
12					
13					
14					
15					

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY

PIMPRI CHINCHWAD MUNICIPAL CORPORATION

(W/S) DIVISION



REPORT OF CHEMICAL EXAMINATION OF WATER

NAME - Rasiklal M. Dhariwal International School.
ADDRESS - Chinchwad.
SOURCE - PCMC Water.

No-WS/LAB/149/2026.
Date - 06/05/2026.
Date of Receipt - 05/05/2026.
Date of Examination - 05/05/2026

Sr.No.	Tests	I. S Standards for Drinking Water	Result mg/lit	Result mg/lit	Conclusion
1	Turbidity	1 N. T. U. Max	1.90 NTU.		
2	pH	6.5 to 8.5	7.24		
3	Total Hardness (as CaCO ₃)	200 mg/lit	60 mg/lit.		
4	Chloride	250 mg/lit	14 mg/lit.		
5	Calcium	75 mg/lit	12.82 mg/lit.		

NOTE - SAMPLE NOT DRAWN BY THIS LABORATORY


CHIEF CHEMIST
WATER TREATMENT PLANT, NIGDI, PCMC